

PRINTED 03 FEBRUARY 2016 - 2:41PM BY BEN LOCKHART

STM 615 - GRADE 60							
SIZE	LENGTH	WEIGHT (LBS)					
#4	17'-2"	860					
#5	11'-3"	1725					
#4	4'-0"	1021					
Weigh	t	3606					
HR1 to make 79'-4" in deck.							

					-
NCRETE	SCH	EDULE			
17.5cu. concrete	-		psi	(min)	

- 1. Excavation, foundation forms, rebar, and concrete to be furnished by contractor or
- designed for soils with a minimum bearing capacity of 1500 psf and adequate drainage. if soil conditions do not meet these requirements, adjust foundation or soil as required. The design is adequate for a highway surcharge of 300psf.
- 3. Work from centerlines when erecting forms and placing embedded items. Place anchor
- 4. In areas of the country where there is severe freezing, increase the depth of the
- foundation so that the bottom extends below the frost line, or provide a minimum of 12" free draining granular material to prevent frost heave. 5. N.I.S.T. H-44 requires that on the entrance and exit ends of a vehicle scale, there shall

 - 5.2. The length of at least one-half the length of the platform but not required to be
- 5.3. Any slope in the remaining portion of the approach shall ensure ease of vehicle access, ease for testing purposes, and drainage away from the scale.
- installation parameters somewhat different than illustrated on this plan, particularly in regard to pit depth and approaches. In order to ensure compliance, consult the local
- 8. Fairbanks does not recommend using foundation or ground installed guide rails along the sides of the truck scale platform. Damage may occur to the scale if the vehicle hits the quide rail, transferring forces to the platform and the checking system. usage of this

- 1. Install (2) 3/4" x 8'-0" long ground rods to project 4". Tie ground rods to slab rebar.
 - 1.1. One for grounding Intalogix Power Supply. Position the ground rod to match the chosen location for the PPS. The PPS may be located at any section. 1.2. One for grounding scale weighbridge. Place within 3ft of a main beam, at any convenient location. The power supply ground must be separate from weighbridge
- ground, and should be at least 4'-0'' from power supply ground. 2. Install minimum 1 1/2" conduit for cable from junction box to scalehouse. Suitable conduit for low voltage conductor shielded cable must pass through the wall at any point
- above pier tops that is convenient. Conduit to extend a minimum of 2" beyond the surface. Conduit is not supplied from the factory.
- 3. If alternating current (AC) is required near the scale, it shall not run closer than 36" in parallel with any load cell or other signal carrying cable.

